



Italia

Scegli la certezza.  
Aggiungi valore.

## FIRE SAFE TEST CERTIFICATE

TRUNNION BALL VALVE FULL BORE

Size 8"

Class 600 LBS

Drawing: 085-TA-G-T-0600-008-316-D

CERTIFICATE NUMBER: IS-199862-14-10

CLIENT: ZA.VE.RO  
ADDRESS: Via Arturo Biella, 1  
28075 GRIGNASCO (NO)

REPORT NUMBER: FTR Nr:14-2010

SCOPE OF REPORT: Fire Safe test carried out according to:  
API 607 Fifth Edition June 2005

max BAR: 76

max °C : 800



CERTIFICATION DATE

28/06/2010



TÜV ITALIA S.R.L.  
TÜV SÜD Group

Direzione e Sede Amministrativa:  
Via Giosuè Carducci, 125 edificio 23  
20099 Sesto San Giovanni (MI)  
Sede legale: Via Mauro Macchi, 27 20124 Milano  
Società soggetta al controllo e al coordinamento di  
TÜV SÜD AG

Telefono: +39 02 24130.1  
Telefax: +39 02 24130.399

www.tuv.it

Amministratore Delegato:  
Ing. Andrea Vivi

Registro delle imprese di Milano  
n. iscrizione e Cod. Fisc. 08922920155  
R.E.A. 1255140 - P. IVA 02055510966  
Capitale sociale : Euro 500.000 int. vers.  
Coord. Bancarie: INTESA BCI - CIN J  
c/c: 000018978166 - ABI 03069 - CAB 32934  
IBAN: IT34 J030 6932 9340 0001 8978 166

TÜV ITALIA S.R.L.  
 TÜV SÜD Group  
 Via Giosuè Carducci, 125 edificio 23  
 20099 Sesto San Giovanni (MI)  
 Telefono: +39 02 24130.1  
 Telefax: +39 02 24130.399  
 www.tuv.it



<b>FIRE SAFE TECHNICAL REPORT</b>
<b>FIRE SAVE CERTIFICATE N°: IS-199862-14-10</b>
<b>CLIENT DOSSIER N°: FTR Nr:14-2010</b>

<u>CLIENT:</u>	<b>ZA.VE.RO</b>
<u>ADDRESS:</u>	<b>Via Arturo Biella, 1 28075 GRIGNASCO (NO)</b>

<b>QUALIFIED VALVE</b>	
<u>VALVE SIZE:</u>	<b>8"</b>
<u>VALVE RATING CLASS:</u>	<b>600 LBS</b>
<u>DRAWING N°:</u>	<b>085-TA-G-T-0600-008-316-D</b>
<u>VALVE TIPE:</u>	<b>TRUNNION BALL VALVE FULL BORE</b>
<u>MAX BAR:</u>	<b>76</b>
<u>MAX °C:</u>	<b>800</b>

<u>RANGE AND TYPE OF VALVES COVERED:</u>	<b>Size 8" and larger Class 600 – 800 – 900 lbs</b>
--	---

<b>THE ABOVE MENTIONED VALVE SUCCESSFULLY PASSED THE FIRE SAFE IN ACCORDANCE TO:</b>	
	<b>API 607 Fifth Edition June 2005</b>

<u>NOTES:</u>	
<u>LOCATION AND DATE OF TEST CARRIED OUT:</u>	<b>ZA.VE.RO 28/06/2010</b>

	TÜV INSPECTOR <input type="checkbox"/> Review <input checked="" type="checkbox"/> Witness
Date: <u>11/04/10</u>	Name: <u>[Signature]</u>



Italia

Scegli la certezza.  
Aggiungi valore.

## FIRE SAFE TEST CERTIFICATE

TRUNNION BALL VALVE FULL BORE

Size 8"

Class 600 LBS

Drawing: 085-TA-G-T-0600-008-LF2-D

CERTIFICATE NUMBER: IS-199862-11-10


CLIENT: ZA.VE.RO  
ADDRESS: Via Arturo Biella, 1  
28075 GRIGNASCO (NO)

REPORT NUMBER: FTR Nr:11-2010

SCOPE OF REPORT: Fire Safe test carried out according to:  
API 607 Fifth Edition June 2005

max BAR: 76

max °C : 806



CERTIFICATION DATE

24/06/2010



TÜV ITALIA S.R.L.  
TÜV SÜD Group

Direzione e Sede Amministrativa:  
Via Giosué Carducci, 125 edificio 23  
20099 Sesto San Giovanni (MI)  
Sede legale: Via Mauro Macchi, 27 20124 Milano  
Società soggetta al controllo e al coordinamento di  
TÜV SÜD AG

Telefono: +39 02 24130.1  
Telefax: +39 02 24130.399

www.tuv.it

Amministratore Delegato:  
Ing. Andrea Vvvi

Registro delle imprese di Milano  
n. iscrizione e Cod. Fisc. 08922920155  
R.E.A. 1255140 - P. IVA 02055510966  
Capitale sociale : Euro 500.000 int. vers.  
Coord. Bancarie: INTESA BCI - CIN J  
c/c 0000189/78166 - ABI 03069 - CAB 32934  
IBAN: IT34 J030 6932 9340 0001 8978 166

TÜV ITALIA S.R.L.  
TÜV SÜD Group  
Via Giosuè Carducci, 125 edificio 23  
20099 Sesto San Giovanni (MI)  
Telefono: +39 02 24130.1  
Telefax: +39 02 24130.399  
www.tuv.it



## FIRE SAFE TECHNICAL REPORT

FIRE SAVE CERTIFICATE N°: IS-199862-11-10

CLIENT DOSSIER N°: FTR Nr:11-2010

CLIENT: ZA.VE.RO

ADDRESS: Via Arturo Biella, 1  
28075 GRIGNASCO (NO)

### QUALIFIED VALVE

VALVE SIZE: 8"

VALVE RATING CLASS: 600 LBS

DRAWING N°: 085-TA-G-T-0600-008-LF2-D

VALVE TIPE: TRUNNION BALL VALVE FULL BORE

MAX BAR: 76

MAX °C: 806

RANGE AND TYPE OF VALVES COVERED: Size 8" and larger  
Class 600 – 800 – 900 lbs

**THE ABOVE MENTIONED VALVE SUCCESSFULLY PASSED THE FIRE SAFE IN ACCORDANCE TO:**

API 607 Fifth Edition June 2005

NOTES:

LOCATION AND DATE OF TEST CARRIED OUT: ZA.VE.RO 24/06/2010

